CE DECLARATION OF CONFORMITI

Manufacturer: BMR, Ing. Petr Bečvarovský

Balbínova 252

516 01 Rychnov n.Kn.

Czech Republic ID: 10498338

Product name: Electronic modular devices for DIN rail mounting

Туре	Intended use	Description
PLA34	Multifunction network analyser for	Supply voltage: 100 230 VAC
	monitoring of power quality of main network	100 265 VDC
	parameters in panel mounting design,	24 V AC/DC
	96x96mm.	Frequency: 40 70Hz
		Current range: 0,001 6A
		Voltage range: 10 600 VAC

Other technical specification in the user manual

This device can be operated only by skilled labour for work on electro-technical devices.

CE declaration of conformity was made according to § 12, chapter4, note a) of low No. 22/1997 Sb. Declared devices are, with respecting standard conditions and specified usage, safe in accordance to the requirements and another relevant announcement by statutory rules No. 17/2003 Sb and 18/2003 Sb and standards 1973/23/ES and 1989/336/ES.

Used technical regulations:

- government order No. 17/2003 Sb., which defines the technical requirements on electrical devices of low voltage.
- government order No. 18/2003 Sb., which defines technical requirements on products from EMC point of view.

It is in conformity with the following standards or other normative documents:

EN 61010-1

Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements

IEC 61557-12

Electrical safety in low voltage distribution systems up to 1000 V a.c. and 1500 V d.c.—Equipment for testing, measuring or monitoring of protective measures

EN 61000-6-2

Electromagnetic compatibility (EMC) - Part 6-2: Generic standards - Immunity for industrial environments

EN 61000-2-4

Electromagnetic compatibility (EMC) - Part 2-4: Environment - Compatibility levels in industrial plants for low-frequency conducted disturbances

EN 61000-6-3

Electromagnetic compatibility (EMC) -

Part 6-3: Generic standards - Emission standard for residential, commercial and light-industrial environments

EN 61000-4-30 class S

Electromagnetic compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods



Ing. Petr Bečvarovský Balbínova 252, 516 01 Rychnov n. Kn., Czech Republic

EN 61000-4-7

Electromagnetic compatibility (EMC) - Part 4-7: Testing and measurement techniques - General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto

EN 61000-4-15

Electromagnetic compatibility (EMC) – Part 4-15: Testing and measurement techniques – Flickermeter – Functional and design specifications

EN 50160

Voltage characteristics of electricity supplied by public electricity networks

EN 50470-3

Electricity metering equipment (a.c.) - Part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

class B: x/1 calss C: x/5

Rychnov nad Kněžnou: 14.9.2013 Name and signature:

Ing. Petr Bečvarovský Balbínova 252 516 01 Rychnov nad Kněži IČO: 10498338, DIČ: 253-65987